

BUKTI KORESPONDENSI
ARTIKEL JURNAL NASIONAL TERAKREDITASI

SINTA 2

Judul artikel : Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration

Jurnal : Journal Informatics - Telecommunication – Electronics (Jurnal Infotel) Vol. 15, No. 4, November 2023

Penulis : **Rusilawati**, Irfan, Gusti Eddy Wirapratama, Istiyo Winarno

No.	Perihal	Tanggal
1.	Bukti konfirmasi submit artikel dan artikel yang disubmit	22 Agustus 2023
2.	Bukti konfirmasi review dan hasil review pertama	22 September 2023
3.	Bukti konfirmasi submit revisi pertama, respon kepada reviewer, dan artikel yang diresubmit	27 September 2023
4.	Bukti konfirmasi artikel accepted	2 November 2023
5.	Bukti artikel dikirim ke bagian produksi	13 November 2023
6.	Bukti konfirmasi artikel published online	November 2023

**1. Bukti Konfirmasi Submit Artikel
dan Artikel yang Disubmit
(22 Agustus 2023)**

Pre Review

Participants

Rusilawati Rusilawati (rusilawati)

Messages

Note

From

PRE REVIEW

bitapargazen

Dear Authors

Aug 22

Thank you for submitting the manuscript. Your effort is highly appreciated.

Before forwarding to reviewers, please ensure your article meets the following crucial points as follows:

Make sure the introduction is written correctly; the composition of the introduction section is (1) a brief description of the problem stated in the manuscript, (2) a review of previous works related to the problem, (3) The analysis of the research gap and state what is your research contribution and (4) What is your research objective. The limitations of the study must be more highlighted clearly.

The minimum number of your references is 20, and 50% should be international journals or international conferences. Please use recent references; the manuscript should be supported by the citation of to last ten years' references. References to web links are unacceptable as authors should only refer reviewed content in journals, proceedings, or books.

Please have your paper proofread to increase the readability level and correct grammatical errors.

The author should add the future scope at the end of the paper, i.e., the author's future work by taking this particular paper as the research base.

Please separate the results and the discussion section.

Please write results that are urgent and directly related to the article title.

Please discuss the Analysis section in-depth, comparing the results of previous researchers.

Please all of the authors are listed in the submission metadata

IMPORTANT! All co-authors' data (full names, e-mails, and affiliations) should be provided to the electronic submission system in the order they will be listed on the publication. It should be done in the second step of the submission "Step 3. Entering the Submission's Metadata". For more than one, use the "Add Author" button. Take care of the order of the authors. First of all, enter the first author. This is not only an annoying formality. If you don't give all authors they won't be listed in various indexing services and won't appear in the printed version!

We recommend you reduce the similarity index by paraphrasing similar sentences. INFOTEL published a high-quality paper with a low similarity index (<15%).

Please use a reference manager (ZOTERO/END NOTE/MENDELEY) to avoid human error in writing reference style. Please ensure that there is no missing information on your references metadata.

Please answer these points strictly in this chat box:

Best regards

Editor

- ▶ 1. The introduction in this paper is already written correctly, which consists of brief description (paragraph 1), a review of previous works (paragraph 2,3), analysis of research gap and contribution (paragraph 4), and research objective (paragraph 5).
- 2. The limitation of the study is stated clearly in introduction section - paragraph 5.
- 3. The number of references: 26, all of them are international journals/conferences and not older than 10 years (2015 – 2022).
- 4. The paper is already grammatically checked with proper application (Grammarly).
- 5. The future scope is already stated in section V (Conclusion and Future Work).
- 6. Results and Discussion had been separated.
- 7. The results are urgent and directly related to the article title.
- 8. In the discussion section, depth analysis and comparison were presented.
- 9. All the authors had been listed in the submission metadata.
- 10. This paper had been checked using TURNITIN, with similarity index result is 9%, the result of the similarity index attached below.
- 11. We use MENDELEY as a reference manager.

rusilawati

Aug 22

 rusilawati, Draft_Jurnal_Infotel_English-edit_2.docx.pdf

Add Message

View Metadata ✕

Section *

Electronics

Submission Language

English

Submissions in several languages are accepted. Choose the primary language of the submission from the pulldown above. *

Prefix

Examples: A, The

Title *

Analysis of voltage and frequency stability of electric power system network with ...

Subtitle

The optional subtitle will appear after a colon (:), following the main title.

Abstract *

sources in the power system using the Virtual Synchronous Generator (VSG) control technique. The VSG is a control alteration that enhances the capabilities of the power system so that voltage and frequency stability can be preserved and improved. The VSG control method with additional damping controllers that increase inertia with additional virtual inertia is used to simulate the speed of restoration of voltage and frequency stability of the power system due to the penetration of PV-based power plants. The simulation results show that at the time of penetration of PV-based power plants in the power system, there is a momentary instability in voltage and frequency, but it is immediately damped by VSG control and can be quickly restored so that the stability of voltage and frequency is maintained.

Powered by TinyMCE

List of Contributors

Name	E-mail	Role	Primary Contact	In Browse Lists
Rusilawati Rusilawati	habsyi.sila@gmail.com	Author	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Irfan Irfan	ipang7377@gmail.com	Author		<input checked="" type="checkbox"/>
Gusti Eddy Wirapratama	gang.adhyaksa1@gmail.com	Author		<input checked="" type="checkbox"/>
Istiyo Winarno	istiyo.winarno@hangtuah.ac.id	Author		<input checked="" type="checkbox"/>

Cover Image

Submission Metadata

These specifications are based on the Dublin Core metadata set, an international standard used to describe journal content.

Additional Refinements

Keywords

Distributed Generator Renewable Energy Voltage Stability Frequency Stability

Virtual Synchronous Generator Control

OpenAIRE ProjectID

If this research resulted from an EU initiative that complies with the [OpenAIRE](#) metadata platform, please include the ProjectID, a six-digit number which corresponds with the Grant Agreement identifier.



Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration

Rusilawati^{1*}, Irfan¹, Gusti Eddy Wirapratama¹, Istiyo Winarno²

¹Teknik Elektro Universitas Islam Kalimantan Muhammad Arsyad Al Banjari

²Teknik Elektro, Universitas Hang Tuah, Surabaya

¹Jalan Adhyaksa No. 2 Kayutangi, Banjarmasin 70124, Indonesia

²Jl. Arif Rahman Hakim no. 150, Keputih, Surabaya 60111, Indonesia

*habsyi.sila@gmail.com

Received, Revised, Accepted

Abstract — The operation of Distributed Generation (DG) with renewable energy sources integrated with distribution networks through microgrids poses challenges in terms of operation and control. If this is left unchecked, it can have a negative impact on system security and reliability in terms of voltage and frequency stability that will be disrupted because of frequent variations in power production and loading levels. This study investigates voltage and frequency stability in microgrids because of the penetration of DG with photovoltaic (PV) renewable energy sources in the power system using the Virtual Synchronous Generator (VSG) control technique. The VSG is a control alteration that enhances the capabilities of the power system so that voltage and frequency stability can be preserved and improved. The VSG control method with additional damping controllers that increase inertia with additional virtual inertia is used to simulate the speed of restoration of voltage and frequency stability of the power system due to the penetration of PV-based power plants. The simulation results show that at the time of penetration of PV-based power plants in the power system, there is a momentary instability in voltage and frequency, but it is immediately damped by VSG control and can be quickly restored so that the stability of voltage and frequency is maintained.

Keywords – Distributed Generator, Renewable Energy, Voltage Stability, Frequency Stability, Virtual Synchronous Generator Control

Copyright © 2018 JURNAL INFOTEL

All rights reserved.

1. INTRODUCTION

The demand for electrical energy is increasing quickly in accordance with growth in the economy. In the development of electric power systems, electric energy service providers are required to be able to supply electrical energy on demand with good quality. Because conventional energy resource reserves, especially fossil fuel, are rapidly diminishing, power generation utilizing renewable energy resources has become one of the most exciting issues to research in recent years. Furthermore, traditional fossil fuels emit a high level of pollution and contribute to an increase in the Glasshouse effect. Renewable energy sources

include wind, solar, and clean water-based power generating sources, on the other hand, are pollution-free. These problems lead to a new trend of electrical energy generation at the distribution level using non-conventional/renewable energy generation such as wind power, solar cells, fuel cells, mini-hydro and others. Therefore, fuels with renewable energy-based energy sources can replace conventional fossil fuels for power generation such as oil, coal, and natural gas [1].

Clean and fast-growing renewable energy sources have considerable availability to utilize and are not costly. However, the uncertain nature of renewable energy sources poses challenges in terms of operation

and control when integrated with existing grids. If left uncontrolled, this can have a negative impact on the security and reliability of the system [2], [3], [4], [5], [6], [7].

The usage of Distributed Generation (DG) can improve overall system efficiency, minimize transmission losses, decrease pollution, and assure the continued operation of electrical energy distribution. However, the drastic increase in the use of DG creates problems in the form of voltage and frequency stability that will be disturbed due to rapid changes in generation and loading levels [8], [9]. In the case of an imbalanced condition, a proper control approach can recover the stability of the system. In operation, DG is linked to the distribution network via a microgrid.

In the research conducted on reference [8], [10] the control scheme for microgrid based on droop control is discussed. However, in contrast to Synchronous Generators (SGs), droop control based DGs still lack inertia, which is adversely affecting the frequency dynamics. To overcome the lack of inertia, a control technique that effectively generates virtual inertia and damping through an electronic inverter is developed. The development of electronic inverters based on special control techniques is called Virtual Synchronous Generator (VSG) [9], [11], [12], [13], [14], [15], [16], [17], [18].

In this study, to control the stability of voltage and frequency in the event of penetration of power plants with PV sources in the power system network, the Virtual Synchronous Generator (VSG) control technique is used with an additional damping controller so as to increase inertia with additional virtual inertia. The VSG control approach is used in simulations to assess the recovery rate of voltage and frequency stability of the power system according to the penetration of PV-based power plants.

2. RESEARCH METHOD

II.1. Distributed Generation

The term "distributed generation" (DG) refers to a small-scale power-producing technology that is positioned near load centers. The DG energy sources could be classified as renewable (wind, solar, hydro, biomass) or non-renewable (diesel, steam, fuel cell). Because of its distributed location, DG can be connected with the distribution system to meet the load demand. The advantages of DG technology include improving the voltage profile and efficiency of electric power distribution. However, the addition of DG can also have a negative impact on frequency and voltage due to rapid changes in generation levels when disturbances occur [8].

II.2. Microgrid

Microgrid is a unified control consisting of several DGs and interconnected loads. Microgrids can operate through two modes of operation, namely grid-connected and disconnected from the main grid, which namely islanding [8], [19]. The goal of microgrids is to deliver electric power sustainably, economically, and safely with intelligent monitoring, control, and recovery technologies [20].

Microgrids integrate with power systems and information systems, having the capability of delivering electrical power back to the larger network during failures in the grid or power outages. Microgrid networks are more sensitive due to the lack of inertia, so when load changes occur, frequency deviations can result, which can degrade the stability of the microgrid [21].

II.3. Virtual Synchronous Generator

DG based on renewable energy sources connected to the main power system through electronic inverters [22]. In comparison to normal synchronous generation, the electronic inverter responds quickly, and the control is quite flexible. In the case of a disturbance, synchronous generators offer the required inertia and damping for stabilizing the power system. Electronic inverters, on the other hand, lack inertia and damping properties. The absence of inertia and damping in electronic inverters causes severe stability problems when a fault or disturbance occurs [11], [16].

Addressing the disadvantage of these electronic inverters [23], a special control technique was developed that effectively generates virtual inertia and damping through an electronic inverter. Virtual Synchronous Generator (VSG) is an electronic inverter that uses a specific control technique. VSG was designed to duplicate the dynamic behaviors of a synchronous generator. VSG functions, however, have restrictions, such as fluctuations in active and reactive power regulation and rapid frequency variations. VSGs are more adaptable and simpler to operate than synchronous generators. VSG characteristics can be modified in real-time, providing great flexibility when compared to synchronous generators.

VSGs are designed to integrate and enhance the stability of power systems based on renewable energy sources. A simple VSG, however, cannot ensure the stability of renewable energy source-based electric power systems. Hence, various modifications and refinements are made in VSG control to improve the stability of the system [13].

II.4. Structure of the VSG

Figure 1 depicts the DG's block diagram, which includes the VSG structure. In Figure 2 the simple structure of a VSG can be seen.




Figure 1. Distributed Generator's Block Diagram including VSG structure




Figure 2. Simple structure of the VSG

VSG consists of DG unit, energy storage, DC/AC converter, filter circuit, governor, and grid [11], [16]. While the electricity from the DG and storage of energy is supposed to represent the prime mover's input torque, the DC/AC converter is believed to be an electromechanical energy transformer connecting the stator and rotor. The electromotive force of the VSG is thus represented by the fundamental component of the electrical voltage midpoint. The value of the resistance and inductance of the filtering unit indicates the impedance of the stator winding.

According to Figure 2, V_{abc} dan i_{abc} are the inverter's alternating current side voltage and current, respectively. V_{oabc} dan i_{oabc} are the LC filter voltage and current, V_{gabc} is the grid voltage. While R , L_f and C_f are filter resistance, inductance, and capacitance, respectively. L_g is the gridline inductance, E and δ are the internal potential amplitude and phase angle of the VSG, V and θ are the voltage amplitude and phase angle of the VSG terminals. P_e , P_m , Q_e , and Q_m is the active power and reactive power generated by the VSG.

VSGs are typically installed between distributed sources of energy and electrical power systems, as seen in Figure 1. As a result, specific control mechanisms that imitate the electromagnetic and mechanical movements of a synchronous generator are an important aspect of VSG development. It is also in charge of active power and frequency modulation, as well as reactive power and voltage management.

The simple swing equation of the SG is used as the core part of the VSG, as described in Equation (1):

$$J \frac{d\omega}{dt} = T_m - T_e - D (\omega - \omega_r) \frac{d\delta}{dt} = \omega \quad (1)$$

where: ω = virtual angular frequency
 ω_r = reference angular frequency
 T_m = mechanical torque
 T_e = electromagnetic torque
 δ = power angle
 D = damping coefficient
 J = moment of inertia of the rotor

The electrical formulation of the synchronous generator's stator is simulated without taking consideration of the electromagnetic connectivity between the stator and rotor while modeling the electromagnetic features of SG for VSG, and can be expressed as Equation (2):

$$L_f \frac{di_{abc}}{dt} = e_{abc} - V_{abc} - Ri_{abc} \quad (2)$$

The active power loop of the VSG simulates the SG's main frequency regulation, damping, and inertia to determine the reference phase and frequency of the signal being modulated. The reactive power loop, which simulates the voltage regulation of the SG, calculates the modulating signal amplitude. The VSG is built around the general and basic swing equation of the SG, and is expressed as Equation (3):

$$P_m - P_e = 2J \frac{d\omega}{dt} - D (\omega - \omega_r) \quad (3)$$

with: P_m = inverter input power
 P_e = inverter output power

The coefficient of virtual damping was crucial in keeping the VSG's speed equal to the grid frequency. Equation (4) describes the mathematical formulas for the VSG's active power loop, which includes the VSG fundamental governor.

$$J \frac{d\omega}{dt} = \frac{P_m}{\omega} - \frac{P_e}{\omega} - D (\omega - \omega_r) \quad (4)$$

The mathematical equation for the VSG reactive power loop can be expressed in Equation (5):

$$K \frac{dE_r}{dt} = Q_m - Q_e + k_q (V_r - V) \quad (5)$$

where: K = inertia coefficient of reactive power
- voltage of the reactive power loop
 E_r = virtual electromotive force
 Q_m = reactive power reference
 Q_e = reactive power output
 K_q = reactive power coefficient-voltage droop
 V = output voltage amplitude
 V_r = voltage amplitude rating

II.5. VSG Control Operation

The input/output control of VSG is attained by the corresponding working mechanism of the inverter on its interface. The control method is the joint control of active power and reactive power control, voltage and frequency control, and droop control. In general, the strategy of applying control to the system depends on the type of operation of the power system.

The characteristics of the inverter and VSG are almost the same, the only difference is that the VSG replicates the characteristics of the SG through its control algorithm and has the further benefit of additional virtual inertia to the system [21]. There are two classifications of VSG control algorithms: active and reactive power control and voltage and frequency control.

The VSG's active and reactive power loops are depicted in Figure 3. The active power-frequency control strategy is represented in Figure 4, and the reactive power-voltage control approach is depicted in Figure 5.




Figure 3. Active power and reactive power loops of the VSG




Figure 4. VSG structure for active power and frequency control with simple governor




Figure 5. VSG control for reactive power and voltage control

Currently, most VSG control techniques utilize

active power and active reactive power control methods due to their simplicity [11], [16], [24]. The advantage of this method is the ability to distribute active power according to its capacity when the VSG is operated in parallel. When operating in the grid connection model, the reactive power controller unit failed to meet the power demand, so an additional unit is needed to increase the reactive power controller functions. Thus, it can provide the desired reactive power supply to the system.

Furthermore, as compared to active power management, reactive power control can easily be impacted by line impedance, load variations, and other factors, causing control results to depart from the needed characteristics and, eventually, leading to reactive power distribution inaccuracy. To suppress the impedance and load fluctuation effects, various control modifications are introduced. For example, adaptive parameter estimation and selection techniques, and virtual impedance control methods to reduce output voltage. These techniques are effective to control and get a better effect for VSG reactive voltage control.

II.5.1. Frequency control - active power

According to Equation (3), active power control could be accomplished by adjusting the frequency change. To suppress frequency fluctuations, the DG can modify its reference power in response to frequency changes. The damping unit, contrary, causes the DG to decrease oscillation.

II.5.2. Voltage Control - reactive power

The reactive power-voltage control structure is equivalent to the traditional SG control system. The characteristics of reactive power-voltage gain are determined by the value of K_q . According to equation (5), reactive power is gradually managed by reducing its impact on the system under specific situations. This control loop incorporates proportional and integral controllers, which are used to control the output voltage based on the changed reference value. It should be mentioned that the primary elements for replicating the SG characteristics are the energy storage system and the electronic inverter. In addition, an extra damping controller is used to inhibit the system's frequency oscillation. Figure 6 depicts the VSG with an additional damping control.




Figure 6. VSG with additional damping control

II.6. VSG for PV system

Distributed power sources, such as PV are mostly connected to the power distribution grid through electronic inverters [25]. In general, PV power systems are categorized as low-voltage and medium-voltage distribution power systems. When multiple PV power systems are connected to each other or to the grid, there will be special difficulties on the power quality and stability of the power system [1], [11].

Particularly, the VSG of a PV power system can demonstrate a frequency dynamic response similar to that of the SG. However, unlike the SG, the power converter is not able to absorb/deliver any kinetic energy, thus requiring an extra energy storage system. Therefore, it is required the implementation and coordination of energy storage system control in the VSG of PV power systems.

Figure 7 shows the application of VSG in a distributed power system with RE. The grid-connected PV through DC/DC converter with MPPT and energy storage system is illustrated in Figure 8. [1], [26]. The MPPT mode controls the PV to maximize the power output. The energy storage system is applied to smoothen the active power output and reduce the negative impact on the grid.




Figure 7. VSG application on distributed power system with RE




Figure 8. Solar PV system with MPPT and energy storage system

3. RESULT

To investigate the effect of VSG control on voltage and frequency stability during the penetration of PV-based systems in the power system, simulations were made using MATLAB/SIMULINK. In Figure 9 and Figure 10, it can be seen the voltage and frequency response of the grid when PV penetration occurs in the system.




Figure 9. Grid voltage response during PV penetration




Figure 10. Grid frequency response during PV penetration

In Figure 11 and Figure 12, voltage and frequency responses of the grid can be clearly depicted when PV penetration occurs, and load is applied.




Figure 11. Grid voltage response during PV penetration and load addition




Figure 12. Grid frequency response during PV penetration and load addition

In Figure 13 and Figure 14, it can be seen the voltage and frequency response of the grid during PV penetration in the system with VSG and without inertia.




Figure 13. Grid voltage response during PV penetration with VSG and without inertia




Figure 14. Grid frequency response during PV penetration with VSG and without inertia

In Figure 15 and Figure 16, it can be seen the voltage and frequency response of the grid when PV penetration occurs in a system with VSG and inertia.




Figure 15. Grid voltage response during PV penetration with VSG and inertia




Figure 16. Grid frequency response during PV penetration with VSG and inertia

4. DISCUSSION

In the research conducted on reference [8], [10] the control scheme for microgrid based on droop control is discussed. However, in contrast to Synchronous Generators (SGs), droop control based DGs still lack inertia, which is adversely affecting the frequency dynamics. The use of VSGs with additional damping controllers that can increase inertia with additional virtual inertia has been proven to reduce voltage and frequency fluctuations caused by the penetration of PV sources in the power system.

From Figure 9 and Figure 10, it can be observed the voltage and frequency response of the grid when PV penetration occurs in the system. At the 5th second, the amplitude of voltage and frequency were affected significantly by the penetration of the PV.

From Figure 11 and Figure 12, voltage and frequency responses of the grid can be clearly depicted when PV penetration occurs, and load is applied. At the 2nd second, as the result before, the amplitude of voltage and frequency fluctuated during the penetration. At the 5th and 7th second, the load connected to the system. This load addition also affected the amplitude of voltage and frequency.

From Figure 13 and Figure 14, the voltage and frequency response of the grid during PV penetration in the system with VSG and without inertia can be observed. Although VSG has been added to the system, the voltage and frequency still fluctuate, as be seen in the 5th second. The combination of PV penetration with VSG can provide active voltage control and help

mitigate voltage fluctuations caused by intermittent PV generation. On the other hand, the absence of inertia can make the grid voltage response more sensitive to changes in power injections.

Figure 15 and Figure 16, illustrate the voltage and frequency reaction of the grid when PV penetration occurs in a system with VSG and inertia. The voltage and frequency fluctuations caused by PV penetration are well dampened, as depicted at the 3rd and 5th seconds. This occurs due to the addition of VSG with inertia.

V. CONCLUSION AND FUTURE WORK

This research introduced the use of Virtual Synchronous Generator (VSG) control technique with an additional damping controller. The VSG control can provide additional virtual inertia to control the stability of voltage and frequency during the penetration of PV-based power plants into the power system network. The results showed that during the penetration of PV-based power plants into the power system, there was a momentary instability in voltage and frequency. However, by implementing VSGs and inertia-enhancing technologies, PV penetration can be managed more effectively, enabling smoother grid integration, and maintaining grid stability, both in terms of voltage and frequency. Hence, the stability of voltage and frequency was well-maintained.

Advanced control techniques for VSGs that effectively duplicate the inertia and damping behavior of synchronous generators could be discovered in the future. The challenging thing in the research is the investigation on how these control strategies can be optimized to address both short-term frequency stability and longer-term voltage stability.

1. REFERENCES

- [1] S. Wenju, G. Wenyong, D. Shaotao, T. Chenyu, Y. Suhang dan T. Yuping, "Virtual Synchronous Generator, a Comprehensive Overview," *Energies*, vol. 15, no. 6148, pp. 1 - 29, 2022.
- [2] K. Ehsanul, K. Pawan, K. Sandeep, A. A. Adedeji dan K. Ki-Hyun, "Solar energy: Potential and future prospects," *Renewable and Sustainable Energy Reviews*, vol. 82, pp. 894 - 900, 2018.
- [3] S. Rahman, S. Saha, S. N. Islam, M. T. Arif, M. Mosadeghy, M. E. Haque dan A. M. T. Oo, "Analysis of Power Grid Voltage Stability with High Penetration of Solar PV Systems," *IEEE Transactions on Industry Applications*, 2021.
- [4] F. Saber, A. T. Seyed dan S. Mohammad, "Smart Deregulated Grid Frequency Control in Presence of Renewable Energy Resources by EVs Charging Control," *IEEE Transactions on Smart Grid*, pp. 1 - 13, 2016.
- [5] Y. Y. Kah, R. S. Charles dan M.-Y. L. Joanne, "Virtual Inertia-Based Inverters for Mitigating Frequency Instability in Grid-Connected Renewable Energy System: A Review," *Applied Sciences*, vol. 9, no. 5300, pp. 1 - 29, 2019.
- [6] H. Thiesen, C. Jauch dan A. Gloe, "Design of a System Substituting Today's Inherent Inertia in the European Continental Synchronous Area," *Energies*, pp. 1 -12, 2016.
- [7] R. Rijo dan M. F. Francis, "Power control strategy of photovoltaic plants for frequency regulation in a hybrid power system," *Electrical Power and Energy Systems*, vol. 110, pp. 171 - 183, 2019.
- [8] C. Ilhami, A.-N. Mohammed, B. Ramazan dan E. Hossain, "Voltage and Frequency Stability Analysis of AC Microgrid," dalam *2015 IEEE International Telecommunications Energy Conference (INTELEC)*, Nankai, Osaka, Japan, 2015.
- [9] L. Jia, M. Yushi dan I. Toshifumi, "Comparison of Dynamic Characteristics between Virtual Synchronous Generator and Droop Control in Inverter-Based Distributed Generators," *IEEE Transactions on Power Electronics*, 2015.
- [10] T. Kato, Y. Kimpara, Y. Tamakoshi, Kurimoto, T. Funabashi dan S. Sugimoto, "An Experimental Study on Dual P-f Droop Control of Photovoltaic Power Generation for Supporting Grid Frequency Regulation," dalam *ScienceDirect IFAC PapersOnLine*, 2018.
- [11] K. M. Cheema, "A comprehensive review of virtual synchronous generator," *Electrical Power and Energy Systems*, vol. 120, pp. 1 -10, 2020.
- [12] M. Chen, D. Zhou dan F. Blaabjerg, "Modelling, Implementation, and Assessment of Virtual Synchronous Generator in Power Systems," *JOURNAL OF MODERN POWER SYSTEMS AND CLEAN ENERGY*, pp. 1 - 13, 2019.
- [13] J. Chen, M. Liu, F. Milano dan T. O'Donnell, "100% Converter-Interfaced generation using virtual synchronous generator control: A case study based on the irish system," *Electric Power Systems Research*, pp. 1 - 10, 2020.
- [14] C. Daniel, E. A. A. Arthur, S. A. Thiago, S. L. S. Domingos, F. F. Jussara dan F. E. Lucas, "Adaptive Armature Resistance Control of Virtual Synchronous Generators to Improve

- Power System Transient Stability,” *Energies*, vol. 13, no. 2365, pp. 1 - 17, 2020.
- [15] W. Li, H. Wang, Y. Jia, S. Yang dan H. Liu, “Frequency Control Strategy of Grid-connected PV System Using Virtual Synchronous Generator,” dalam *2019 IEEE PES Innovative Smart Grid Technologies Asia*, 2019.
- [16] M. C. Khalid, I. C. Naveed, F. T. Muhammad, M. Kashif, M. Muhammad, K. Muhammad, H. M. Ahmad dan E. Z.M. Salem, “Virtual Synchronous Generator: Modifications, Stability Assessment and Future Applications,” *Elsevier*, pp. 1704 -1717, 2022.
- [17] C. Zhong, H. Li, Y. Zhou, Y. Lv, J. Chen dan Y. Li, “Virtual synchronous generator of PV generation without energy storage for frequency support in autonomous microgrid,” *International Journal of Electrical Power and Energy Systems*.
- [18] W. Alfandi, Khairudin dan N. Soedjarwanto, “VIRTUAL SYNCHRONOUS GENERATOR UNTUK KOMPENSASI INERSIA PADA SISTEM MICROGRID,” *Jurnal Informatika dan Teknik Elektro Terapan (JITET)*, vol. 10, no. 2, pp. 58 - 62, 2022.
- [19] H. Xiaochao, S. Yao, Z. Xin, L. Jinghang, W. Peng dan M. G. Josep, “Improvement of Frequency Regulation in VSG-Based AC Microgrid via Adaptive Virtual Inertia,” *IEEE Transactions on Power Electronics*, pp. 1 -14, 2019.
- [20] Y. Ben, G. Junke, Z. Changxin, G. Zhiyong, Y. Jinshan dan L. Fei, “A Review on Microgrid Technology with Distributed Energy,” dalam *2017 International Conference on Smart Grid and Electrical Automation*, 2017.
- [21] Z. Cheng, L. Huayi, Z. Yang, L. Yueming, C. Jikai dan L. Yang, “Virtual synchronous generator of PV generation without energy storage for frequency support in autonomous microgrid,” *International Journal of Electrical Power and Energy Systems*.
- [22] B. Kroposki, B. Johnson, Y. Zhang, V. Gevorgian, P. Denholm, Hodge, Bri-Mathias dan B. Hannegan, “Achieving a 100% Renewable Grid: Operating Electric Power Systems with Extremely High Levels of Variable Renewable Energy,” *IEEE Power & Energy Magazine*, 2017.
- [23] S. W. Azeem, K. Mehmood, K. M. Cheema, M. F. Tahir dan A. M. El-Sherbeeney, “Dual-transformer-based hybrid resonant three-level ZCS converter,” *Energy Reports*, pp. 421 - 429, 2021.
- [24] Y. Hirase, K. Abe, K. Sugimoto, K. Sakimoto, H. Bevrani dan T. Ise, “A novel control approach for virtual synchronous generators to suppress frequency and voltage fluctuations in microgrids,” *Applied Energy*, pp. 1 - 12, 2017.
- [25] R. S. Mahmood, S. N. R. Rizvi, D. M. Y. Javed, K. M. Cheema, A. R. Tariq dan M. Waqas, “A Comprehensive approach to Study Double Diode Model and Shading Effects on Photovoltaic Arrays,” dalam *2020 IEEE 23rd International Multitopic Conference (INMIC)*, 2020.
- [26] X. Yan, J. Li, L. Wang, S. Zhao, T. Li, Z. Lv dan M. Wu, “Adaptive-MPPT-Based Control of Improved Photovoltaic Virtual Synchronous Generators,” *energies*, vol. 11, no. 1834, pp. 1 - 18, 2018.

**2. Bukti Konfirmasi Review dan
Hasil Review Pertama
(22 September 2023)**



Notifications

**[INFOTEL] Editor Decision**

2023-09-22 03:18 AM

Rusilawati Rusilawati, Irfan Irfan, Gusti Eddy Wirapratama, Istiyo Winarno:

We have reached a decision regarding your submission to JURNAL INFOTEL, "Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration".

Our decision is: Revisions Required

Please submit your revision file include:

1. Revisions Form [download](#)
2. **Please indicate your revision with a highlight in a different color**

--The deadline for submitting the revised results is a maximum of 14 days--

Bitu Parga Zen
Institut Teknologi Telkom Purwokerto
bitu@itttelkom-pwt.ac.id

Reviewer B:

The authors show hard work and excellent writing skills so the paper is qualified to be accepted in this journal. While some minor grammar issues are found (please use proofreaders like Grammarly) and some pictures are unclear, this paper looks good overall. Also on page 2, there is a sentence with 9 citations which I think is too many. Usually 2-3 citations are enough.

Recommendation: Accept Submission

Reviewer C:

I have gone through the submitted manuscript and the following are my comments:

- 1) "...The operation of Distributed Generation (DG) with renewable energy sources integrated with distribution networks through microgrids poses challenges in terms of operation and control. If this is left unchecked, it can have a negative impact on system security and reliability in terms of voltage and frequency stability that will be disrupted because of frequent variations in power production and loading levels..."
You need to state how this problem has been solved before, and point out the issues with these current solutions.
- 2) Just before Section II, "RESEARCH METHOD", articulate the major contributions of this work. This should be preferably in point form.
- 3) The clarity of all figures must be improved.
- 4) You need to discuss the implications of all the observed results.
- 5) Add some future research scope in the 'CONCLUSSION AND FUTURE WORK' section.

Recommendation: Revisions Required

Best Regard,

Editor-in-Chief
[JURNAL INFOTEL](#)

Eko Fajar Cahyadi, Ph.D.

**3. Bukti Konfirmasi Submit Revisi Pertama,
Respon kepada Reviewer,
dan Artikel yang Diresubmit
(27 September 2023)**

JURNAL INFOTEL
Tasks
English View Site rusilawati

Submission Library
View Metadata

Analysis of voltage
Rusilawati Rusilawati

Submissions

Submission

Round 1

Round 1 Status
Submission accepted

Notifications

- [\[INFOTEL\] Editor Decision](#) 2023-09-22 03:18 AM
- [\[INFOTEL\] Editor Decision](#) 2023-09-26 05:41 AM
- [\[INFOTEL\] Editor Decision](#) 2023-11-02 01:55 AM
- [\[INFOTEL\] Editor Decision](#) 2023-11-13 06:41 AM

Revision Confirmation ✕

Participants [Edit](#)

Rusilawati Rusilawati (rusilawati)

Ridwan Pandiya (ridwanpandiya)

Messages

Note	From
Dear The Journal Editor, We have read the comment from the reviewers, and we've understand it. We confirm that we will submit the revision before the due date. Thank you	rusilawati Sep 27

[Add Message](#)

Reviewer's Attachments [Q Search](#)

No Files

Revisions [Q Search](#) [Upload File](#)

▶		5378-1 Article Text, Draft_Jurnal_Infotel_English-edit_rev5.docx	Article Text
▶		5379-1 Other, Revisions Form Jurnal INFOTEL.docx	Other

Review Discussions [Add discussion](#)

Name	From	Last Reply	Replies	Closed
▶ Revision Confirmation	rusilawati Sep/27	-	0	<input type="checkbox"/>

[Public](#)

[Knowledge](#)

[Project](#)

REVISION FORM JURNAL INFOTEL

Author(s): Rusilawati, Irfan, Gusti Eddy Wirapratama, Istiyo Winarno

Title: Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration

The referees' comments concerning our manuscript were extremely helpful to us in preparing a clearer version. We have revised our manuscript according to the referees' and editor's suggestions. We have marked in blue the parts that have been changed in the revised manuscript or explained. The main revised parts are briefly described as follows:

REVIEWER COMMENTS

Reviewer 1: Comments to the Author

1. Reviewer comments

The authors show hard work and excellent writing skills, so the paper is qualified to be accepted in this journal. While some minor grammar issues are found (please use proofreaders like Grammarly) and some pictures are unclear, this paper looks good overall. Also on page 2, there is a sentence with 9 citations which I think is too many. Usually, 2-3 citations are enough.

Author Reply:

- We have revised the grammar issue which found in the manuscript, using Grammarly.
- The unclear pictures have been improved.
- The sentence in page 2 have been revised.

Reviewer 2: Comments to the Author

1. Reviewer comments

"...The operation of Distributed Generation (DG) with renewable energy sources integrated with distribution networks through microgrids poses challenges in terms of operation and control. If this is left unchecked, it can have a negative impact on system security and reliability in terms of voltage and frequency stability that will be disrupted because of frequent variations in power production and loading levels..."

You need to state how this problem has been solved before and point out the issues with these current solutions.

Author Reply:

The problem which solved using this current method have been added and stated in the paragraph.

1. The operation of Distributed Generation (DG) with renewable energy sources integrated with distribution networks through microgrids poses challenges in terms of operation and control. The drastic increase in the use of DG creates problems in the form of voltage and frequency stability that will be disturbed due to rapid changes in generation and loading levels. If this condition left unchecked, it could have a negative impact on system security and reliability in terms of voltage and frequency stability that will be disrupted because of frequent variations in power production and loading levels.
 2. The VSG control method with additional damping controllers that increase inertia with additional virtual inertia is used to simulate the speed of restoration of voltage and frequency stability of the power system due to the penetration of PV-based power plants.
-

2. Reviewer comments

Just before Section II, "RESEARCH METHOD ", articulate the major contributions of this work. This should be preferably in point form.

Author Reply:

We've described the major contributions of this work, in point form, before Section II. The contribution could be described as:

The stability of voltage and frequency in the event of penetration of power plants with PV sources in the power system network need to control. In this study, the authors proposed the Virtual Synchronous Generator (VSG) control technique with an additional damping controller. This proposed method could increase inertia which impact to the stability of voltage and frequency of the systems. The VSG control approach is used in simulations to assess the recovery rate of voltage and frequency stability of the power system according to the penetration of PV-based power plants.

3. Reviewer comments

The clarity of all figures must be improved.

Author Reply:

The pictures have been improved.

4. Reviewer comments

You need to discuss the implications of all the observed results.

Author Reply:

The discussion of all the observed results had been added in the manuscript. (Added with blue texted sentences)

5. Reviewer comments

Add some future research scope in the 'CONCLUSION AND FUTURE WORK' section.

Author Reply:

Some future research scope had been added in the 'CONCLUSION AND FUTURE WORK' section. (Added with blue texted sentences)



Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration

Rusilawati^{1*}, Irfan¹, Gusti Eddy Wirapratama¹, Istiyo Winarno²

¹Teknik Elektro Universitas Islam Kalimantan Muhammad Arsyad Al Banjari

²Teknik Elektro, Universitas Hang Tuah, Surabaya

¹Jalan Adhyaksa No. 2 Kayutangi, Banjarmasin 70124, Indonesia

²Jl. Arif Rahman Hakim no. 150, Keputih, Surabaya 60111, Indonesia

*habsyi.sila@gmail.com

Received, Revised, Accepted

Abstract — The operation of Distributed Generation (DG) with renewable energy sources integrated with distribution networks through microgrids poses challenges in terms of operation and control. **The drastic increase in the use of DG creates problems in the form of voltage and frequency stability that will be disturbed due to rapid changes in generation and loading levels.** If this condition left unchecked, it could have a negative impact on system security and reliability in terms of voltage and frequency stability that will be disrupted because of frequent variations in power production and loading levels. This study investigates voltage and frequency stability in microgrids because of the penetration of DG with photovoltaic (PV) renewable energy sources in the power system using the Virtual Synchronous Generator (VSG) control technique. The VSG is a control alteration that enhances the capabilities of the power system so that voltage and frequency stability can be preserved and improved. **The VSG control method with additional damping controllers that increase inertia with additional virtual inertia is used to simulate the speed of restoration of voltage and frequency stability of the power system due to the penetration of PV-based power plants.** The simulation results show that at the time of penetration of PV-based power plants in the power system, there is a momentary instability in voltage and frequency, but it is immediately damped by VSG control and can be quickly restored so that the stability of voltage and frequency is maintained.

Keywords – Distributed Generator, Renewable Energy, Voltage Stability, Frequency Stability, Virtual Synchronous Generator Control

Copyright © 2018 JURNAL INFOTEL

All rights reserved.

5. INTRODUCTION

The demand for electrical energy is increasing quickly in accordance with growth in the economy. In the development of electric power systems, electric energy service providers are required to be able to supply electrical energy on demand with good quality. Because conventional energy resource reserves, especially fossil fuel, are rapidly diminishing, power generation utilizing renewable energy resources has become one of the most exciting issues to research in recent years. Furthermore, traditional fossil fuels emit

a high level of pollution and contribute to an increase in the Glasshouse effect. Renewable energy sources include wind, solar, and clean water-based power generating sources, on the other hand, are pollution-free. These problems lead to a new trend of electrical energy generation at the distribution level using non-conventional/renewable energy generation such as wind power, solar cells, fuel cells, mini-hydro and others. Therefore, fuels with renewable energy-based energy sources can replace conventional fossil fuels for power generation such as oil, coal, and natural gas [1].

Clean and fast-growing renewable energy sources have considerable availability to utilize and are not costly [2]. However, the uncertain nature of renewable energy sources poses challenges in terms of operation and control when integrated with existing grids. If left uncontrolled, this can have a negative impact on the security and reliability of the system [3], [4]. The increased penetration of variable generation into power system management and control has a significant impact on frequency control. Because renewable energy sources inject uncertainties into the power system, greater spinning reserve is required to adjust for generation and demand imbalances [5], [6], [7].

The usage of Distributed Generation (DG) can improve overall system efficiency, minimize transmission losses, decrease pollution, and assure the continued operation of electrical energy distribution. However, the drastic increase in the use of DG creates problems in the form of voltage and frequency stability that will be disturbed due to rapid changes in generation and loading levels [8], [9]. In the case of an imbalanced condition, a proper control approach can recover the stability of the system. In operation, DG is linked to the distribution network via a microgrid.

In the research conducted on reference [8], [10] the control scheme for microgrid based on droop control is discussed. However, in contrast to Synchronous Generators (SGs), droop control based DGs still lack inertia, which is adversely affecting the frequency dynamics [9]. To overcome the lack of inertia, a control technique that effectively generates virtual inertia and damping through an electronic inverter is developed. The development of electronic inverters based on special control techniques is called Virtual Synchronous Generator (VSG) [11], [12], [13]. During disturbances, the VSG inertia constant could dampen frequency oscillations. To improve frequency stability, a damping coefficient and inertia constant adaption control are used [14], [15]. The VSG may operate in both grid-connected and islanded modes. The VSG experiences various stability issues during power system or microgrid disturbances, depending on the nature of the disturbance [16], [17], [18].

The stability of voltage and frequency in the event of penetration of power plants with PV sources in the power system network need to control. In this study, the authors proposed the Virtual Synchronous Generator (VSG) control technique with an additional damping controller. This proposed method could increase inertia which impact to the stability of voltage and frequency of the systems. The VSG control approach is used in simulations to assess the recovery rate of voltage and frequency stability of the power system according to the penetration of PV-based power plants.

6. RESEARCH METHOD

II.1. *Distributed Generation*

The term "distributed generation" (DG) refers to a small-scale power-producing technology that is positioned near load centers. The DG energy sources could be classified as renewable (wind, solar, hydro, biomass) or non-renewable (diesel, steam, fuel cell). Because of its distributed location, DG can be connected with the distribution system to meet the load demand. The advantages of DG technology include improving the voltage profile and efficiency of electric power distribution. However, the addition of DG can also have a negative impact on frequency and voltage due to rapid changes in generation levels when disturbances occur [8].

II.2. *Microgrid*

Microgrid is a unified control consisting of several DGs and interconnected loads. Microgrids can operate through two modes of operation, namely grid-connected and disconnected from the main grid, which namely islanding [8], [19]. The goal of microgrids is to deliver electric power sustainably, economically, and safely with intelligent monitoring, control, and recovery technologies [20].

Microgrids integrate with power systems and information systems, having the capability of delivering electrical power back to the larger network during failures in the grid or power outages. Microgrid networks are more sensitive due to the lack of inertia, so when load changes occur, frequency deviations can result, which can degrade the stability of the microgrid [21].

II.3. *Virtual Synchronous Generator*

DG based on renewable energy sources connected to the main power system through electronic inverters [22]. In comparison to normal synchronous generation, the electronic inverter responds quickly, and the control is quite flexible. In the case of a disturbance, synchronous generators offer the required inertia and damping for stabilizing the power system. Electronic inverters, on the other hand, lack inertia and damping properties. The absence of inertia and damping in electronic inverters causes severe stability problems when a fault or disturbance occurs [11], [16].

Addressing the disadvantage of these electronic inverters [23], a special control technique was developed that effectively generates virtual inertia and damping through an electronic inverter. Virtual Synchronous Generator (VSG) is an electronic inverter that uses a specific control technique. VSG was designed to duplicate the dynamic behaviors of a synchronous generator. VSG functions, however, have restrictions, such as fluctuations in active and reactive power regulation and rapid frequency variations. VSGs are more adaptable and simpler to operate than synchronous generators. VSG

characteristics can be modified in real-time, providing great flexibility when compared to synchronous generators.

VSGs are designed to integrate and enhance the stability of power systems based on renewable energy sources. A simple VSG, however, cannot ensure the stability of renewable energy source-based electric power systems. Hence, various modifications and refinements are made in VSG control to improve the stability of the system [13].

II.4. Structure of the VSG

Figure 1 depicts the DG's block diagram, which includes the VSG structure. In Figure 2 the simple structure of a VSG can be seen.




Figure 1. Distributed Generator's Block Diagram including VSG structure




Figure 2. Simple structure of the VSG

VSG consists of DG unit, energy storage, DC/AC converter, filter circuit, governor, and grid [11], [16]. While the electricity from the DG and storage of energy is supposed to represent the prime mover's input torque, the DC/AC converter is believed to be an electromechanical energy transformer connecting the stator and rotor. The electromotive force of the VSG is thus represented by the fundamental component of the electrical voltage midpoint. The value of the resistance and inductance of the filtering unit indicates the impedance of the stator winding.

According to Figure 2, V_{abc} dan i_{abc} are the inverter's alternating current side voltage and current, respectively. V_{oabc} dan i_{oabc} are the LC filter voltage and current, V_{gabc} is the grid voltage. While R , L_f and C_f are filter resistance, inductance, and capacitance, respectively. L_g is the gridline inductance, E and δ are the internal potential amplitude and phase angle of the VSG, V and θ are the voltage amplitude and phase angle of the VSG terminals. P_e , P_m , Q_e , and Q_m is the active power and reactive power generated by the

VSG.

VSGs are typically installed between distributed sources of energy and electrical power systems, as seen in Figure 1. As a result, specific control mechanisms that imitate the electromagnetic and mechanical movements of a synchronous generator are an important aspect of VSG development. It is also in charge of active power and frequency modulation, as well as reactive power and voltage management.

The simple swing equation of the SG is used as the core part of the VSG, as described in Equation (1):

$$J \frac{d\omega}{dt} = T_m - T_e - D (\omega - \omega_r) \frac{d\delta}{dt} = \omega \quad (1)$$

where: ω = virtual angular frequency
 ω_r = reference angular frequency
 T_m = mechanical torque
 T_e = electromagnetic torque
 δ = power angle
 D = damping coefficient
 J = moment of inertia of the rotor

The electrical formulation of the synchronous generator's stator is simulated without taking consideration of the electromagnetic connectivity between the stator and rotor while modeling the electromagnetic features of SG for VSG, and can be expressed as Equation (2):

$$L_f \frac{di_{abc}}{dt} = e_{abc} - V_{abc} - Ri_{abc} \quad (2)$$

The active power loop of the VSG simulates the SG's main frequency regulation, damping, and inertia to determine the reference phase and frequency of the signal being modulated. The reactive power loop, which simulates the voltage regulation of the SG, calculates the modulating signal amplitude. The VSG is built around the general and basic swing equation of the SG, and is expressed as Equation (3):

$$P_m - P_e = 2J \frac{d\omega}{dt} - D (\omega - \omega_r) \quad (3)$$

with: P_m = inverter input power
 P_e = inverter output power

The coefficient of virtual damping was crucial in keeping the VSG's speed equal to the grid frequency. Equation (4) describes the mathematical formulas for the VSG's active power loop, which includes the VSG fundamental governor.

$$J \frac{d\omega}{dt} = \frac{P_m}{\omega} - \frac{P_e}{\omega} - D (\omega - \omega_r) \quad (4)$$

The mathematical equation for the VSG reactive power loop can be expressed in Equation (5):

$$K \frac{dE_r}{dt} = Q_m - Q_e + k_q (V_r - V) \quad (5)$$

where: K = inertia coefficient of reactive power
- voltage of the reactive power loop
 E_r = virtual electromotive force
 Q_m = reactive power reference
 Q_e = reactive power output
 K_q = reactive power coefficient-voltage droop
 V = output voltage amplitude
 V_r = voltage amplitude rating

II.5. VSG Control Operation

The input/output control of VSG is attained by the corresponding working mechanism of the inverter on its interface. The control method is the joint control of active power and reactive power control, voltage and frequency control, and droop control. In general, the strategy of applying control to the system depends on the type of operation of the power system.

The characteristics of the inverter and VSG are almost the same, the only difference is that the VSG replicates the characteristics of the SG through its control algorithm and has the further benefit of additional virtual inertia to the system [21]. There are two classifications of VSG control algorithms: active and reactive power control and voltage and frequency control.




Figure 3. Active power and reactive power loops of the VSG




Figure 4. VSG structure for active power and frequency control with simple governor




Figure 5. VSG control for reactive power and voltage control

The VSG's active and reactive power loops are depicted in Figure 3. The active power-frequency control strategy is represented in Figure 4, and the reactive power-voltage control approach is depicted in Figure 5.

Currently, most VSG control techniques utilize active power and active reactive power control methods due to their simplicity [11], [16], [24]. The advantage of this method is the ability to distribute active power according to its capacity when the VSG is operated in parallel. When operating in the grid connection model, the reactive power controller unit failed to meet the power demand, so an additional unit is needed to increase the reactive power controller functions. Thus, it can provide the desired reactive power supply to the system.

Furthermore, as compared to active power management, reactive power control can easily be impacted by line impedance, load variations, and other factors, causing control results to depart from the needed characteristics and, eventually, leading to reactive power distribution inaccuracy. To suppress the impedance and load fluctuation effects, various control modifications are introduced. For example, adaptive parameter estimation and selection techniques, and virtual impedance control methods to reduce output voltage. These techniques are effective to control and get a better effect for VSG reactive voltage control.

II.5.1. Frequency control - active power

According to Equation (3), active power control could be accomplished by adjusting the frequency change. To suppress frequency fluctuations, the DG can modify its reference power in response to frequency changes. The damping unit, contrary, causes the DG to decrease oscillation.

II.5.2. Voltage Control - reactive power

The reactive power-voltage control structure is equivalent to the traditional SG control system. The characteristics of reactive power-voltage gain are determined by the value of K_q . According to equation (5), reactive power is gradually managed by reducing its impact on the system under specific situations. This control loop incorporates proportional and integral controllers, which are used to control the output voltage based on the changed reference value. It should be mentioned that the primary elements for replicating the SG characteristics are the energy storage system and the electronic inverter. In addition, an extra damping controller is used to inhibit the system's frequency oscillation. Figure 6 depicts the VSG with an additional damping control.

II.6. VSG for PV system

Distributed power sources, such as PV are mostly connected to the power distribution grid through electronic inverters [25]. In general, PV power systems are categorized as low-voltage and medium-

voltage distribution power systems. When multiple PV power systems are connected to each other or to the grid, there will be special difficulties on the power quality and stability of the power system [1], [11].




Figure 6. VSG with additional damping control

Particularly, the VSG of a PV power system can demonstrate a frequency dynamic response similar to that of the SG. However, unlike the SG, the power converter is not able to absorb/deliver any kinetic energy, thus requiring an extra energy storage system. Therefore, it is required the implementation and coordination of energy storage system control in the VSG of PV power systems.

Figure 7 shows the application of VSG in a distributed power system with RE. The grid-connected PV through DC/DC converter with MPPT and energy storage system is illustrated in Figure 8. [1], [26]. The MPPT mode controls the PV to maximize the power output. The energy storage system is applied to smoothen the active power output and reduce the negative impact on the grid.




Figure 7. VSG application on distributed power system with RE




Figure 8. Solar PV system with MPPT and energy storage system

7. RESULT

To investigate the effect of VSG control on voltage and frequency stability during the penetration of PV-based systems in the power system, simulations were made using MATLAB/SIMULINK. In Figure 9 and Figure 10, it can be seen the voltage and frequency response of the grid when PV penetration occurs in the system.




Figure 9. Grid voltage response during PV penetration




Figure 10. Grid frequency response during PV penetration




Figure 11. Grid voltage response during PV penetration and load addition

In Figure 11 and Figure 12, voltage and frequency responses of the grid can be clearly depicted when PV penetration occurs, and load is applied.




Figure 12. Grid frequency response during PV penetration and load addition

In Figure 13 and Figure 14, it can be seen the voltage and frequency response of the grid during PV penetration in the system with VSG and without inertia.




Figure 13. Grid voltage response during PV penetration with VSG and without inertia




Figure 14. Grid frequency response during PV penetration with VSG and without inertia

In Figure 15 and Figure 16, it can be seen the voltage and frequency response of the grid when PV penetration occurs in a system with VSG and inertia.




Figure 15. Grid voltage response during PV penetration with VSG and inertia




Figure 16. Grid frequency response during PV penetration with VSG and inertia

8. DISCUSSION

In the research conducted on reference [8], [10] the control scheme for microgrid based on droop control is discussed. However, in contrast to Synchronous Generators (SGs), droop control based DGs still lack inertia, which is adversely affecting the frequency dynamics. The use of VSGs with additional damping controllers that can increase inertia with additional virtual inertia has been proven to reduce voltage and frequency fluctuations caused by the penetration of PV sources in the power system.

From Figure 9 and Figure 10, it can be observed the voltage and frequency response of the grid when PV penetration occurs in the system. At the 5th second, the amplitude of voltage and frequency were affected significantly, instability condition, by the penetration of the PV.

From Figure 11 and Figure 12, voltage and frequency responses of the grid can be clearly depicted when PV penetration occurs, and load is applied. At the 2nd second, as the result before, the amplitude of voltage and frequency fluctuated during the penetration. At the 5th and 7th second, the load connected to the system. This load addition also affected the amplitude of voltage and frequency, out from stability condition.

From Figure 13 and Figure 14, the voltage and frequency response of the grid during PV penetration in the system with VSG and without inertia can be observed. Although VSG has been added to the system, the voltage and frequency still fluctuate, as be seen in the 5th second. The combination of PV penetration with VSG can provide active voltage control and help mitigate voltage fluctuations caused by intermittent PV generation. On the other hand, the absence of inertia can make the grid voltage response more sensitive to changes in power injections.

Figure 15 and Figure 16, illustrate the voltage and frequency reaction of the grid when PV penetration occurs in a system with VSG and inertia. The voltage and frequency fluctuations caused by PV penetration are well dampened, as depicted at the 3rd and 5th seconds. This occurs due to the addition of VSG with inertia. The proposed method could stabilize the fluctuating voltage and frequency during the PV penetration.

V. CONCLUSION AND FUTURE WORK

This research introduced the use of Virtual Synchronous Generator (VSG) control technique with an additional damping controller. The VSG control can provide additional virtual inertia to control the stability of voltage and frequency during the penetration of PV-based power plants into the power system network. The results showed that during the penetration of PV-based power plants into the power system, there was a momentary instability in voltage and frequency.

However, by implementing VSGs and inertia-enhancing technologies, PV penetration can be managed more effectively, enabling smoother grid integration, and maintaining grid stability, both in terms of voltage and frequency. Hence, the stability of voltage and frequency was well-maintained.

In the future works, the authors will develop the advanced control techniques for VSGs, such as Hybrid PI-Fuzzy control method, which hopefully could duplicate the inertia and damping behavior of synchronous generators more precise. The challenging thing in the research is the investigation on how these control strategies can be optimized to address both short-term frequency stability and longer-term voltage stability.

1. REFERENCES

- [1] S. Wenju, G. Wenyong, D. Shaotao, T. Chenyu, Y. Suhang dan T. Yuping, "Virtual Synchronous Generator, a Comprehensive Overview," *Energies*, vol. 15, no. 6148, pp. 1 - 29, 2022.
- [2] K. Ehsanul, K. Pawan, K. Sandeep, A. A. Adedeji dan K. Ki-Hyun, "Solar energy: Potential and future prospects," *Renewable and Sustainable Energy Reviews*, vol. 82, pp. 894 - 900, 2018.
- [3] S. Rahman, S. Saha, S. N. Islam, M. T. Arif, M. Mosadeghy, M. E. Haque dan A. M. T. Oo, "Analysis of Power Grid Voltage Stability with High Penetration of Solar PV Systems," *IEEE Transactions on Industry Applications*, 2021.
- [4] F. Saber, A. T. Seyed dan S. Mohammad, "Smart Deregulated Grid Frequency Control in Presence of Renewable Energy Resources by EVs Charging Control," *IEEE Transactions on Smart Grid*, pp. 1 - 13, 2016.
- [5] Y. Y. Kah, R. S. Charles dan M.-Y. L. Joanne, "Virtual Inertia-Based Inverters for Mitigating Frequency Instability in Grid-Connected Renewable Energy System: A Review," *Applied Sciences*, vol. 9, no. 5300, pp. 1 - 29, 2019.
- [6] H. Thiesen, C. Jauch dan A. Gloe, "Design of a System Substituting Today's Inherent Inertia in the European Continental Synchronous Area," *Energies*, pp. 1 -12, 2016.
- [7] R. Rijo dan M. F. Francis, "Power control strategy of photovoltaic plants for frequency regulation in a hybrid power system," *Electrical Power and Energy Systems*, vol. 110, pp. 171 - 183, 2019.
- [8] C. Ilhami, A.-N. Mohammed, B. Ramazan dan E. Hossain, "Voltage and Frequency Stability Analysis of AC Microgrid," dalam *2015 IEEE International Telecommunications Energy Conference (INTELEC)*, Nankai, Osaka, Japan, 2015.
- [9] L. Jia, M. Yushi dan I. Toshifumi, "Comparison of Dynamic Characteristics between Virtual Synchronous Generator and Droop Control in Inverter-Based Distributed Generators," *IEEE Transactions on Power Electronics*, 2015.
- [10] T. Kato, Y. Kimpara, Y. Tamakoshi, Kurimoto, T. Funabashi dan S. Sugimoto, "An Experimental Study on Dual P-f Droop Control of Photovoltaic Power Generation for Supporting Grid Frequency Regulation," dalam *ScienceDirect IFAC PapersOnLine*, 2018.
- [11] K. M. Cheema, "A comprehensive review of virtual synchronous generator," *Electrical Power and Energy Systems*, vol. 120, pp. 1 -10, 2020.
- [12] M. Chen, D. Zhou dan F. Blaabjerg, "Modelling, Implementation, and Assessment of Virtual Synchronous Generator in Power Systems," *JOURNAL OF MODERN POWER SYSTEMS AND CLEAN ENERGY*, pp. 1 - 13, 2019.
- [13] J. Chen, M. Liu, F. Milano dan T. O'Donnell, "100% Converter-Interfaced generation using virtual synchronous generator control: A case study based on the irish system," *Electric Power Systems Research*, pp. 1 - 10, 2020.
- [14] C. Daniel, E. A. A. Arthur, S. A. Thiago, S. L. S. Domingos, F. F. Jussara dan F. E. Lucas, "Adaptive Armature Resistance Control of Virtual Synchronous Generators to Improve Power System Transient Stability," *Energies*, vol. 13, no. 2365, pp. 1 - 17, 2020.
- [15] W. Li, H. Wang, Y. Jia, S. Yang dan H. Liu, "Frequency Control Strategy of Grid-connected PV System Using Virtual Synchronous Generator," dalam *2019 IEEE PES Innovative Smart Grid Technologies Asia*, 2019.
- [16] M. C. Khalid, I. C. Naveed, F. T. Muhammad, M. Kashif, M. Muhammad, K. Muhammad, H. M. Ahmad dan E. Z.M. Salem, "Virtual Synchronous Generator: Modifications, Stability Assessment and Future Applications," *Elsevier*, pp. 1704 -1717, 2022.
- [17] C. Zhong, H. Li, Y. Zhou, Y. Lv, J. Chen dan Y. Li, "Virtual synchronous generator of PV generation without energy storage for frequency support in autonomous microgrid," *International Journal of Electrical Power and Energy Systems*.
- [18] W. Alfandi, Khairudin dan N. Soedjarwanto, "Virtual Synchronous Generator Untuk Kompensasi Inersia Pada Sistem Microgrid," *Jurnal Informatika dan Teknik Elektro Terapan (JITET)*, vol. 10, no. 2, pp. 58 - 62, 2022.
- [19] H. Xiaochao, S. Yao, Z. Xin, L. Jinghang, W. Peng dan M. G. Josep, "Improvement of Frequency Regulation in VSG-Based AC Microgrid via Adaptive Virtual Inertia," *IEEE*

Transactions on Power Electronics, pp. 1 -14, 2019.

- [20] Y. Ben, G. Junke, Z. Changxin, G. Zhiyong, Y. Jinshan dan L. Fei, "A Review on Microgrid Technology with Distributed Energy," dalam *2017 International Conference on Smart Grid and Electrical Automation*, 2017.
- [21] Z. Cheng, L. Huayi, Z. Yang, L. Yueming, C. Jikai dan L. Yang, "Virtual synchronous generator of PV generation without energy storage for frequency support in autonomous microgrid," *International Journal of Electrical Power and Energy Systems*.
- [22] B. Kroposki, B. Johnson, Y. Zhang, V. Gevorgian, P. Denholm, Hodge, Bri-Mathias dan B. Hannegan, "Achieving a 100% Renewable Grid: Operating Electric Power Systems with Extremely High Levels of Variable Renewable Energy," *IEEE Power & Energy Magazine*, 2017.
- [23] S. W. Azeem, K. Mehmood, K. M. Cheema, M. F. Tahir dan A. M. El-Sherbeeney, "Dual-transformer-based hybrid resonant three-level ZCS converter," *Energy Reports*, pp. 421 - 429, 2021.
- [24] Y. Hirase, K. Abe, K. Sugimoto, K. Sakimoto, H. Bevrani dan T. Ise, "A novel control approach for virtual synchronous generators to suppress frequency and voltage fluctuations in microgrids," *Applied Energy*, pp. 1 - 12, 2017.
- [25] R. S. Mahmood, S. N. R. Rizvi, D. M. Y. Javed, K. M. Cheema, A. R. Tariq dan M. Waqas, "A Comprehensive approach to Study Double Diode Model and Shading Effects on Photovoltaic Arrays," dalam *2020 IEEE 23rd International Multitopic Conference (INMIC)*, 2020.
- [26] X. Yan, J. Li, L. Wang, S. Zhao, T. Li, Z. Lv dan M. Wu, "Adaptive-MPPT-Based Control of Improved Photovoltaic Virtual Synchronous Generators," *energies*, vol. 11, no. 1834, pp. 1 - 18, 2018.

**4. Bukti Konfirmasi Artikel Accepted
(2 November 2023)**



Notifications

**[INFOTEL] Editor Decision**

2023-11-02 01:55 AM

Rusilawati Rusilawati, Irfan Irfan, Gusti Eddy Wirapratama, Istiyo Winarno:

Letter of Acceptance (LoA)

On behalf of the Editor, we are pleased to inform that your submission to JURNAL INFOTEL, "Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration" **is Accepted**

Here are some important things we would like you to do in relation to manuscript acceptance:

1. Please kindly complete the payment by below scheme
 - The cost paid by Author with Indonesia citizenship is Rp 1,500,000 (IDR)
 - The cost paid by non-Indonesia citizenship is \$100 (USD)

The payment should be transferred to the following

Bank Name : Bank BNI 46
Account Holder : Institut Teknologi Telkom Purwokerto
Holder Address : Jl. D.I. Panjaitan No. 128, Purwokerto
Account Number : 1282222128

2. Confirm your payment through our email on: infotel@ittelkom-pwt.ac.id by uploading the scan of the receipt of payment and put remarks for any details we need to concern.
with Subject: PAYMENT-[INFOTEL_VOLUMEXX_NUMBERXX_YOURNAME]

3. Fill in the Copyright Transfer Form document and send the document along with scan of the receipt of payment. [Download Copyright Transfer Form](#)

4. Please send all **high-resolution figure files** of your article to email infotel@ittelkom-pwt.ac.id

We thank you a lot for your participation and again congratulate for your achievement, we are looking forward to seeing you at the next issue

Ridwan Pandiyya
Institut Teknologi Telkom Purwokerto
ridwanpandiyya@ittelkom-pwt.ac.id

Best Regard,

Editor-in-Chief
[JURNAL INFOTEL](#)

Eko Fajar Cahyadi, Ph.D.

**5. Bukti Artikel Dikirim Ke Bagian Produksi
(13 November 2023)**

12:21

84%

Rusilawati, Analysis of voltage and frequency stability of electric power system ...
ejournal.ittelkom-pwt.ac.id

Notifications

[INFOTEL] Editor Decision

2023-11-13 06:41 AM

Rusilawati Rusilawati, Irfan Irfan, Gusti Eddy Wirapatama, Istiyo Winarno:

The editing of your submission, "Analysis of Voltage and Frequency Stability of Electric Power System Network with Photovoltaic-Based Generation Penetration," is complete. We are now sending it to production.

Submission URL: <https://ejournal.ittelkom-pwt.ac.id/index.php/infotel/authorDashboard/submission/1022>

Bitu Parga Zen
Institut Teknologi Telkom Purwokerto
bitu@ittelkom-pwt.ac.id

Best Regard,

Editor-in-Chief
[JURNAL INFOTEL](#)

Eko Fajar Cahyadi, Ph.D.

**6. Bukti Artikel Published Online
(November 2023)**



Submissions

Submissions

My Queue

Archives

Help

Archived Submissions

New Submission

Search

1022 Rusilawati Rusilawati, Irfan Irfan, Gusti Eddy Wi...
Analysis of voltage and frequency stability of electr...

Published

1

1 Production galleys created

0 Open discussions